

Date TBD

Ms. Royann Winchester
Tesoro Refining and Marketing Company
P.O. Box 817
Wilmington, CA 90748

SUBJECT: A/N 474116- 40CFR63 Subpart UUU Operation, Maintenance and Monitoring Plan for SRU

Dear Ms. Winchester:

The South Coast Air Quality Management District has reviewed your 40CFR63 Subpart UUU Operation, Maintenance and Monitoring Plan (OMMP) dated October 2, 2007 for your SRU. This plan includes information regarding emission limits, monitoring equipment, procedures, equipment maintenance, and quality control plans as detailed in §63.1574(f). A summary of the required information is provided below:

Requirements for Emissions of HAP	
Compliance option	Subject to NSPS
Parameters to be monitored	Reduced sulfur concentration using CEMS at SRU Tail Gas Treating Unit (TGTU) stack SO ₂ concentration using CEMS at SRU incinerator stack
Emission limits	Reduced sulfur ≤ 300 ppmv, (reported as SO ₂ , dry basis, 0% excess air) at TGTU stack SO ₂ ≤ 250 ppmv (dry basis, 0% excess air) at SRU incinerator stack
Operating Parameter Limit	Not applicable
Monitoring Procedure (Emissions)	Collect the hourly average reduced sulfur monitoring data at the TGTU stack according to §63.1572; calculate and record the 12-hour rolling average reduced sulfur concentration, and maintain the 12-hour average reduced sulfur concentration at or below 300 ppmv (reported as SO ₂ , dry basis, 0% excess air) Collect the hourly average SO ₂ monitoring data at the incinerator stack according to §63.1572; calculate and record the 12-hour rolling average SO ₂ concentration, and maintain the 12-hour average SO ₂ concentration at or below 250 ppmv (dry basis, 0% excess air)
Monitoring Schedule	Continuously when SRU is in operation
QA/QC	Per Performance Specification 2 for SO ₂ CEMS [40CFR60 Appendix B], Performance Specification 5 for total reduced sulfur (TRS) CEMS [40CFR60 Appendix B]; and Quality Assurance Procedure 1 [40CFR60 Appendix F] with RATA annually instead of quarterly
Maintenance Schedule	Per manufacturer recommendation
Bypass lines	None

Based on the information submitted, your SRU 40CFR63 Subpart UUU OMMP has been reviewed and approved, subject to the following conditions.

1. Operate at all times according to the procedures in your OMMP.
2. Maintain records to document conformance with the procedures in your OMMP.
3. Submit changes to this OMMP for approval by the Executive Officer [§63.1574(f)(1)].

If you have any questions, regarding this plan, please contact Ms. Janice West at 909-396-3763.

Sincerely,

Jay Chen
Senior Manager
Refinery and Waste Management
Engineering & Compliance

JC:JW

cc: Ed Pupka